

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0067:234

Page 1 of 1

CATEGORY: Photoelectric Smoke Detectors

LISTEE: Siemens Building Technologies, Inc., Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Models FS-DP and FS-DPT photoelectric type smoke detectors. Model FS-DPT employs an integral supplemental 135 °F fixed temperature heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For wall and ceiling mount.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric type smoke detectors for use with separately listed compatible fire alarm control units and Model DB-11 or DB-XIIRS base (CSFM Listing No. 7300-0067:134). Suitable for duct application where air velocity is between 0-4000 ft/min.

XLF: 7272-0065:173

1-24-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JANUARY 24, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager